

DETAIL 1
ASSEMBLY SEQUENCE FOR
TERMINAL PANEL AND EARTH

Refer Note 1

NOTES:


1. Ensure earth connection properly tightened before installing luminaire terminal panel.

ASSOCIATED DEPARTMENTAL DOCUMENTS:
 Standard Drawings
 Specifications


REFERENCED DOCUMENTS:
 Standard Drawings:
 1323 Road Lighting - Luminaire Terminal Panel
 1624 Road Lighting - Junction Box Single Phase Wiring Details
 1625 Road Lighting - Junction Box Three Phase Wiring Details
 1626 Road Lighting - Junction Box Active, Neutral and Earth Bolting Arrangements
 1699 Traffic Signals/Road Lighting/ITS - Parts List

Departmental Specifications:
 MRTS228 Provision of Electrical Switchboards

Australian Standards:
 AS/NZS 3000 Electrical Installations (Wiring Rules)



CONNECTION TO LOCAL
ROAD LIGHTING POLE



REMOTE CONNECTION

⚠ INSTALLATION OF CONDUITS AND PITS IS THE RESPONSIBILITY OF THE LICENSED ELECTRICAL CONTRACTOR

Department of Transport and Main Roads		 Queensland Government	 <small>© The State of Queensland (Department of Transport and Main Roads) 2015 http://creativecommons.org/licenses/by/3.0/au</small>
ROAD LIGHTING			
UNDERPASS LIGHTING WIRING DETAILS		A3 Not to Scale	Standard Drawing No 1637 Date 4/15
A	B		