

Technical Specification

Transport and Main Roads Specifications MRTS16D Hardscape Works

April 2012





Copyright



http://creativecommons.org/licenses/by/3.0/au/

© State of Queensland (Department of Transport and Main Roads) 2014

Feedback: Please send your feedback regarding this document to: mr.techdocs@tmr.qld.gov.au

Contents

1	Introduction1					
2	Definition	efinition of terms and abbreviations1				
3	Standard	tandards				
3.1	Materials	Materials and practices				
4	Quality system requirements					
4.1	Hold Poin	Hold Points and Milestones				
5	General r	General requirements				
5.1	Samples.	•	2			
6	Planting bed edging					
6.1	_	General				
6.2	Material r	ial requirements2				
	6.2.1	Timber planting bed edges				
	6.2.2	Concrete planting bed edges	2			
	6.2.3	Unit paver planting bed edges	3			
	6.2.4	Rock boulder planting bed edges	3			
6.3	Construction					
	6.3.1	General				
	6.3.2	Timber planting bed edging	3			
	6.3.3	Concrete planting bed edging	3			
	6.3.4	Installation of unit paver planting bed edging				
	6.3.5	Installation of rock boulder planting bed edging				
7	Irrigation system					
7.1	General	eneral				
7.2	Material r	aterial requirements				
		the irrigation system				
	7.3.1	General	3			
	7.3.2	Scope	3			
	7.3.3	Design	4			
7.4	Construction					
7.5	Commissioning					
7.6	Warranties, manuals and as constructed drawings					
8	Supplementary requirements5					

1 Introduction

This technical specification applies to the general requirements of hardscape works for road construction and associated works.

This technical specification shall be read in conjunction with MRTS01 *Introduction to Technical Specifications*, MRTS50 *Specific Quality System Requirements* and other technical specifications as appropriate.

This technical specification forms part of the Transport and Main Roads Specifications Manual.

2 Definition of terms and abbreviations

The terms used in this specification shall be as defined in Clause 2 of MRTS01 *Introduction to Technical Specifications*. Landscape and revegetation related terms and abbreviations used in this specification are defined in Table 2 of MRTS16 *General Requirements – Landscape and Revegetation Works*. Guidance on generic landscape and revegetation terms is contained in the department's *Landscape and Revegetation Works User Guideline*.

3 Standards

3.1 Materials and practices

Materials and practices shall be in accordance with, but not limited to, the following Australian Standards:

- a) AS 1477 UPVC pipes and fittings for pressure applications
- b) AS 1604 Specification for preservative treatment
- c) AS 2032 Code of practice for installation of UPVC pipe systems
- d) AS 2033 Installation of polyethylene pipe systems
- e) AS 2053 Conduits and fittings for electrical installations General requirements
- f) AS 2698 Plastics pipes and fittings for irrigation and rural applications Polyethylene microirrigation pipe
- g) AS 2845 Water supply backflow prevention devices Materials, design and performance requirements
- h) AS 3000 Electrical installations
- i) AS 3500 National Plumbing and Drainage Code for water supply connections
- j) AS 4129 Fittings for polyethylene (PE) pipes for pressure applications, and
- k) AS 4130 Polyethylene (PE) pipes for pressure applications.

Materials used for electrical cabling and fittings shall comply with the requirements of MRTS95 *Switchboards and Cables*.

Notwithstanding the above requirements, irrigation systems and materials shall meet the requirements of the applicable Local Government where relevant.

4 Quality system requirements

4.1 Hold Points and Milestones

General requirements for Hold Points and Milestones are specified in Clause 5.2 of MRTS01 *Introduction to Technical Specifications*.

The Hold Points and Milestones applicable to this specification are summarised in Table 4.1.

Table 4.1 - Hold Points and Milestones

Clause	Hold Point	Milestone
5.1		Submission of samples
7.3.3	Submission of irrigation design	
7.5	2. Commissioning of the irrigation system	

5 General requirements

5.1 Samples

The Contractor shall submit to the Administrator, samples of materials in accordance with Clause 5.5 of MRTS16 *General Requirements - Landscape and Revegetation Work.* Milestone

6 Planting bed edging

6.1 General

Planting bed edging operations shall be carried out where shown on the Drawings, or as specified elsewhere in the Contract.

6.2 Material requirements

6.2.1 Timber planting bed edges

Timber shall be softwood that is preservative treated in accordance with AS 1604.1 – Hazard Class 5. Fixings shall be hot dipped galvanised.

Stakes and braces shall be hardwood.

Timber edging type shall be as shown on the Drawings and have dimensions as specified in Table 6.2.1.

Table 6.2.1 – Timber garden edging

Timber Edging Type	Size (mm)	Ancillary Component	Size (mm)
1	3000 x 100 x 15	Bracing	600 x 75 x 15
2	3000 x 150 x 38	Stakes	450 x 50 x 38
3	3000 x 250 x 75	Stakes	450 x 50 x 38

6.2.2 Concrete planting bed edges

Concrete planting bed edging shall consist of Class 20 MPa/20 concrete in accordance with the requirements of MRTS03.

Compaction of subgrade shall be in accordance with the requirements of Clause 15 of MRTS04 *General Earthworks*.

6.2.3 Unit paver planting bed edges

Unit paver planting bed edging shall consist of paving blocks constructed of the material and of the colour shown on the Drawings. Cement mortar shall be in accordance with the requirements of MRTS03.

Concrete strip footings shall be Class 20 MPa/20 in accordance with the requirements of MRTS03.

Compaction of subgrade shall be in accordance with the requirements of Clause 15 of MRTS04 *General Earthworks*.

6.2.4 Rock boulder planting bed edges

Rock boulder planting bed edging shall consist of rock boulders, free of mud and of the type and sizes shown on the Drawings.

6.3 Construction

6.3.1 General

Planting bed edging shall be installed in the locations shown on the Drawings.

6.3.2 Timber planting bed edging

Timber planting bed edging shall be installed in accordance with Standard Drawing 1659.

6.3.3 Concrete planting bed edging

Concrete planting bed edging shall be constructed in accordance with Standard Drawing 1660.

6.3.4 Installation of unit paver planting bed edging

Unit paver planting bed edging shall be installed in accordance with Standard Drawing 1660.

6.3.5 Installation of rock boulder planting bed edging

Rock boulder planting bed edging shall be installed in accordance with Standard Drawing 1660.

7 Irrigation system

7.1 General

Irrigation systems shall be installed where shown on the Drawings or as stated elsewhere in the Contract.

7.2 Material requirements

Materials shall comply with the relevant Australian Standard or technical specification.

7.3 Design of the irrigation system

7.3.1 General

The design intent for the irrigation system shall be to provide a functioning sprinkler and / or drip irrigation system that shall deliver the quantity of water to maintain plant health.

7.3.2 Scope

The extent of the irrigation system shall be as shown in the Drawings or as stated in Item 3 of the Annexure.

7.3.3 Design

The design of the irrigation system shall be carried out by a suitably qualified, certified irrigation designer.

The water supply components shall be designed by a civil engineer with experience in municipal water supply installations.

The 240V electrical components shall be designed by an electrical engineer.

The design and Drawings shall be certified by the consultant organisation which carried out the design.

The documents produced by the design process shall include:

- a) schematic Drawings of the complete irrigation system showing the number and sequence of watering stations and the locations of proposed water filters, water isolation valves, irrigation controller and electrical isolation equipment
- detailed Drawings of the irrigation system showing all pipe installations, sprinkler or dripper emitters, manual or automatic valve details, backflow prevention devices, water filters, rain gauge/weather station/rain sensor, controllers, protection boxes and cabinets, electrical connections and water supply connections
- c) a schedule showing the rates of application of all water outlet devices
- d) material supply specifications
- e) installation specifications
- f) a commissioning schedule and checklist, and
- g) a statement of the design warranty.

Prior to installation, the proposed design shall be submitted to the Administrator for a determination as to its suitability. **Hold Point 1**

7.4 Construction

The irrigation system shall be installed in accordance with the design and the relevant Australian Standard as listed in Clause 3.

All electrical installations shall be installed by a registered Electrical Contractor as defined under the *Electricity Act 1994*.

7.5 Commissioning

The entire irrigation system shall be flushed on completion of installation and each water outlet device shall be removed from the supply line.

Any high or low pressure sections of the irrigation system shall be tested at current local government supply pressure or design operating pressure respectively for a minimum period of 30 minutes.

Automatic controllers shall be tested by individually operating each solenoid valve from the irrigation controller. The irrigation system shall then be tuned and balanced so that the required quantity of water is delivered to each output device and the timer program set.

The Contractor shall provide training to the Administrator in the setting up and operation of the irrigation system.

The Contractor shall notify the Administrator in writing of the completion of the irrigation system prior to the commissioning of the irrigation system. **Hold Point 2**

7.6 Warranties, manuals and as constructed drawings

The Contractor shall provide the construction and installation warranties as required under the Contract. All operating components shall be guaranteed for 12 months or to the end of the Defects Liability Period, whichever is greater, from the date that the irrigation system was commissioned.

The Contractor shall provide five hard copies of a comprehensive operating manual for the irrigation system, including a parts list which sets out the description and suppliers of all operating components.

The Contractor shall provide five hard copies (A3 format) of the As-constructed Drawings and specifications for the irrigation system, together with one copy in editable, electronic format.

8 Supplementary requirements

The requirements of MRTS16D *Hardscape Works* are varied by the supplementary requirements given in Item 4 of the Annexure.

