


**CABLE JOINING PIT  
TYPES 7 AND 8**


TYPE	L1	L2	L3	L4	D	W1	W2	W3	W4	R1
1(J)	515	475	430	405	400	235	195	150	120	40
3	540	500	455	420	520	315	275	230	190	50
4	695	650	605	454	820	390	350	300	240	50
7	1010	960	910	835	1130	560	500	450	375	50
8	1375	1315	1260	960	900	560	500	450	375	50

**NOTES:**


- All corner radii to be 20mm, unless shown otherwise.
- Dimensions are in millimetres unless shown otherwise.
- Permanent Identifying Label(s) shall be attached to the inside of each pit as follows:  
 Type 1(J) and Type 3 Pits: One (1) label at halfway from the top of the pit;  
 Type 4 Pits: One (1) label at 300mm from the top and one (1) label at 300mm from the bottom of the pit;  
 Type 7 and Type 8 Pits: Three (3) labels at 300mm, 600mm and 900mm from the top of the pit.  
 The Permanent Identifying Label shall state "[Manufacturer's Name]", "Date of Manufacture [(month/year)]", and "[weight of product] kg".



**TYPE 1 (J)**



**TYPES 3 AND 4**



**CABLE JOINING PIT  
TYPES 1 (J), 3 AND 4**

**ASSOCIATED DEPARTMENTAL DOCUMENTS:**

Standard Drawings  
Specifications

**REFERENCED DOCUMENTS:**

Departmental Standard Drawings:  
1699 Traffic Signals/Road Lighting/ITS – Parts List

**Departmental Specifications:**

MRTS91 Conduits and Pits

**Australian Standards:**

AS/NZS 3000 Electrical Installations (Wiring Rules)

Department of Transport and Main Roads			
TRAFFIC SIGNALS/ROAD LIGHTING			
A3	Not to Scale	Standard Drawing No	1631
		Date	3/2020
A	B	C	